

# POWER QUALITY IMPROVEMENT IN DISTRIBUTION SYSTEM USING DVR WITH MINIMUM ENERGY INJECTION: AN INTELLIGENT CONTROL SCHEME

P. Murali<sup>1</sup>, D.Kirubakaran<sup>2</sup>

<sup>1</sup>Research Scholar, Anna University, Chennai, India

<sup>2</sup>Supervisor, Department of EEE, St Joseph's Institute of Technology, Chennai, India  
muralipanchanathan@gmail.com

**Abstract**--In the proposed paper, an intelligent control technique Modified Gravitational Search Algorithm (MGSA) for DVR is proposed for power quality (PQ) upgrade of distribution system. The MGSA is a joined execution of the Gravitational Search Algorithm (GSA) and Artificial Neural Network (ANN). The control system elements of HRES are thinking about the informative of PQ inconveniences. In this, the MGSA is done in two stages, the initial step is to generate the dataset using GSA technique and the second step is to develop the dataset for the prediction of duty cycle using ANN. Contingent upon the issues of PQ the MGSA enhances the required amount of control signal to the converter for recoup the initial operating condition. With the help of the proposed technique, the PQ issues are mitigated with advancement in fast execution and closeness to the exact value in decreasing the SAG issues for any sensitive loads connected to the distribution system. Hence this work is executed and assessed using MATLAB/simulink platform at different stages like KF, EKF, PSO and ABC. Thus the proposed work reveals that the examination exhibits the prevalence of the proposed approach and affirms its capability to take care of the PQ issues and upgrade the execution of the DVR in the distribution systems.

**Keywords:** power quality issues, DSTATCOM, associated distribution system, GSA, client power gadgets

## I INTRODUCTION

At perfect sinusoidal voltage with contracted magnitude level and frequency in a perfect way [1] the clients of power distribution system ought to require continuous stream of energy. For all intents and purposes, extraordinary amount of nonlinear loads given by power systems, particularly distribution systems [2, 3], the nature of power supplies are perceptibly influenced. In

view of nonlinear loads destructive substances are included the waveform. By nonlinear loads [4], many power quality issues are additionally delivered. Power quality is a huge issue considering electricity providers, instrument makers and clients. The power quality issues are arranged into a few sorts [5, 6] in view of the distortion happening in voltage waveform. They are (i) Transients, (ii) Short term variations like sag, swell and interruption, (iii) Long term variations like sustained interruption, under and over voltages, (iv) Voltage imbalances such as DC offset, harmonics, inter harmonics, notching and noise and (v) Voltage fluctuations and power frequency variations [7, 8]. To direct the PQ issues in the power distribution system [9] client power gadgets (CPDs) are utilized. Reactive power, filtering of current harmonics, load current balancing and power factor correction [10] are killed by CPD. Presently broadly acknowledged client power gadgets are static synchronous compensator (DSTATCOM) and dynamic voltage restorer (DVR) as they work on voltage source converter (VSC) standard [11, 12]. By the proficient power gadget of series associated power electronic converter called DVR the effects of upstream voltage unsettling influences on delicate loads are directed. For the execution of DVR [13, 14] control methodologies are reasonably used. Zero-succession voltage segment is thought to be zero [15-17] as three wired distribution systems are utilized to associate mechanical loads out of enormous dominant part of DVR control techniques. Subsequently unbalanced sags are not neutralized by other controlling techniques of DVR and they are likewise moderate. The compensation exhibitions of DVR [18] might be enhanced by control algorithms. In this approach, the objective was to improve the PQ in the distribution

system while satisfying the fluctuation of voltage during the fault condition. Here, the hybrid technique of MGSA is utilized to assist the control algorithm of DVR. The proposed technique is clearly described in detail. The remainder of this article is organized as follows, the recent research work and the background of the research work is discussed in Section 2. The proposed technique thorough explanation is explained in Section 3. The suggested technique achievement results and the related discussions are given in Section 4 and the paper is concluded in Section 5.

## II LITERATURE REVIEW

In the assessment of PQ issues, tackling, and controlling in distribution system various research works are accessible in writings. Beneath gives the survey of a few.

The usage of energy from wind in a secured way with greater quality has been clarified by S. Agalar et al. [21]. Two systems were considered for the detailed explanation of wind energy. With the help of static transfer switch (STS), the grid and the wind energy systems are connected in parallel in the first system and similarly in the second system, the dynamic voltage restorer (DVR) was connected with the wind energy system (WES). The aim was, to keep the changes that may occur in the energy that was created with the assistance of DVR system because of the varieties of wind speed. To keep up the power progression and to enhance the power quality is the point of the created systems. An active crowbar protection (ACB\_P) system was proposed by S. Swain et al [22]., for upgrading the fault-ride through (FRT) capacity of DFIG so as to enhance the power nature of the system. In conventional protection scheme, only resistor protection scheme was designed with capacitor in series with the resistor. Reducing the rotor side fault current, regulating the DC voltage, reducing the crowbar operating time in order to disengage the DFIG from the rotor side converter, the short circuit response of terminal voltage and dynamic responses of the DFIG are the principle target of the proposed approach..For welding applications that have output voltage control and current constraining element notwithstanding amid outrageous overloading conditions at the output terminals a power-factor-corrected bridgeless (BL) switched-mode power supply (SMPS) has been portrayed by s. Narula et al. [23]. Working in a continuous conduction mode to achieve unity power factor the front-end of the SMPS comprises of a BL boost converter, while to manage the output voltage at the backside a pulse width modulation isolated full

bridge dc-dc converter was utilized. Demonstrating its fast dynamic response to supply voltage and load varieties the plan and execution of this BL arc welding power supply (AWPS) was displayed. To enhance the power quality (PQ) in a distribution system for a distribution static compensator (DSTATCOM) a dual tree-complex wavelet transform-based control algorithm have been displayed by d. Li et al. [24]. To separate individual line frequency component for the estimation of the reference active power component the misshaped load current of each phase was decayed into different frequency levels with this procedure. To create the reference currents for the control of voltage source converter utilized as DSTATCOM the deviations of separate detected load currents from these assessed reference components are utilized. The answer for power quality management has been researched by V. Khadkikar et al. [25]. The regularly changing scenes in the field of generation and distribution systems have offered ascend to extra PQ difficulties in spite of the fact that the power quality issues, like reactive power compensation, harmonic distortion and fluctuations were found to be regular in power system and power electronics researchers perspective. An open unified power quality conditioner (OUPQC) a fascinating arrangement has been examined by h. Hafezi et al. [26]. Inside the smart domo grid project, co-founded by the Italian Ministry of Economic Development, they additionally talked about the design, simulation and implementation phases related to an open UPQC introduced in a genuine LV distribution grid in the city of Brescia (Italy). To confront power quality issues in distribution networks come about because of the field installation that demonstrates the adequacy of the proposed arrangement. For load compensation applications in three-stage system, K. Venkatraman et al. [27] have exhibited a custom power gadget, named as transformer-less universal power quality conditioner (TUnPQC). Energy systems are one of the most important infrastructures of the modern society. To realize a sustainable, reliable and affordable energy supply, a new energy revolution is now ongoing globally. M A Farahat[28] Energy systems are one of the most important infrastructures of the modern society. To realize a sustainable, reliable and affordable energy supply, a new energy revolution is now ongoing globally. M. Talaat[29] When the load exceeds the generation, the system stability is affected, which leads to cascade outages and shutdown of the major parts of the power system, causing the frequency decay effect. Without a typical dc link the TUnPQC comprises of shunt and series compensators.

### A. Background of the research work

PQ issues has prompted due to the usage of sensitive electronic equipment has expanded. The following are the different PQ disturbances: Transients, Interruptions, Voltage sag, voltage swell, Voltage collapse, Harmonics etc. Particular custom power gadgets are utilized to manage these PQ issues. For the utilization of voltage sag, swell and harmonics DVR is a custom power device utilized. For disentangling the above issues the DVR is quick, flexible and powerful arrangement. With loads in the extent of some MVA, the DVR is proposed for securing the entire plant. Inside couple of milliseconds, the DVR can re-set up the stack voltage. The objective voltage work on which it gives the suitable compensation output voltage of DVR is settled also with the ideal voltage injection angle in perspective of minimum energy compensation. On its control algorithm, the compensation performance of the DVR depends to such an extent. With the ideal balance of the voltage droop to vanquish the voltage sag/swell issue, the control algorithms like artificial neural network (ANN), fuzzy logic control (FLC), genetic algorithm (GA), differential evolutionary (DE) algorithm, simulated annealing (SA) etc, are used together. Putting aside greater chance to execute or settle on the decision tenets, the ANN and FLC are working in view of the training data, so it can't give the proficient dynamic response. It causes infeasible plan with superfluous computational time as the GA, DE and SA operation depends arbitrarily in nature. In the control algorithm it requires assistant support for discovering swell/sag/harmonic issue in system voltages to develop DVR's execution however a few configurations and control strategies are utilized for the DVR. Thus, to lighten the PQ issues in distribution system an upgraded approach is required to enhance the DVR execution. To deal with this issue most works are displayed in writing and the capable results are not given by the showed works. This exploration work has been roused to do because of these issues and disadvantages.

### III PROPOSED CONTROL TECHNIQUE WITH DVR

The proposed block diagram with control structure of DVR is shown in Fig. 1. During voltage sag, the required amount of voltage supplied to the load is supplied by the DVR in associated with the point of common coupling (PCC). The DVR basically comprises of a injection transformer in series with a voltage source converter harmonic filter and an energy storage device connected to the dc-link. The dc link injects or absorbs the required amount of power to compensate the recognized voltage sag. The harmonic content is reduced after the introduction of a filter which is placed in between VSC and injection transformer. Subsequently, the filter changes over the pulse-modulated voltage of the VSC into sinusoidal voltage. The filtered voltage is

injected into distribution system via series-injecting transformer. There are two principle factors identifying with the capacity and execution of DVR conflicting with voltage sags at specific power system, the severity level of sag and the Total Harmonic Distortion. Both of these thus are essentially chosen by the DC source [30]. The accompanying segments quickly depict the demonstrating of the DVR.




Figure. 1 Proposed DVR Structure in Power System

#### A. Modeling Of DVR

An equivalent circuit of DVR is appeared in the fig. 2. In DVR equivalent circuit, load bus fault level decides system impedance  $Z^{sys}$ . At the point when the DVR infusion transformer injects a series voltage, the expected load voltage magnitude is increasing. The voltage level of the DVR can be composed as,

$$V_{DVR}^{inj} = V_l^{sys} + Z^{sys} \cdot I_f^{sys} - V_f^{sys} \quad (1)$$

Where,  $V_l^{sys}$  is the required system load voltage magnitude,  $I_f^{sys}$  is the system load current,  $Z^{sys}$  is the system impedance and  $V_f^{sys}$  is the system voltage during fault condition. Load current can be written as,

$$I_l^{sys} = \frac{P_l^{sys} + jQ_l^{sys}}{V_l^{sys}} \quad (2)$$

Where,  $P_l^{sys}$  and  $Q_l^{sys}$  are the active and reactive power absorbed by the system load. On the off chance that the load voltage is considered as reference shape, the condition (1) can be composed in the accompanying structure.




Figure. 2 Equivalent Structure of DVR

$$V_{DVR}^{inj} (\cos\alpha + j \sin\alpha) = V_f^{sys} + Z^{sys} \cdot I_f^{sys} [\cos(\beta - \phi) + j \sin(\beta - \phi)] - V_f^{sys} (\cos\delta + j \sin\delta) \quad (3)$$

Where,  $\alpha$ ,  $\beta$  and  $\delta$  are the angle of  $V_{DVR}^{inj}$ ,  $Z^{sys}$  and  $V_f^{sys}$  respectively and  $\phi$  is the load power factor angle computed as,

$$\tan\phi = \frac{Q_l^{sys}}{P_l^{sys}} \quad (4)$$

The complex injected power of DVR can be written as,

$$S_{DVR} = V_{DVR}^{inj} \cdot I_f^{sys} \quad (5)$$

The efficient working of the DVR is depending upon the measured voltages at the terminals. The values of measured supply voltages for the proposed system can be communicated by the following matrix as the accompanying structure,

$$V_N^{sys} = \begin{bmatrix} V_a(t) \\ V_b(t) \\ V_c(t) \end{bmatrix} = \begin{bmatrix} V_a \sin(\omega t + \phi_a) \\ V_b \sin(\omega t + \phi_b) \\ V_c \sin(\omega t + \phi_c) \end{bmatrix} \quad (6)$$

The symmetrical components measurement of three phase voltages is defined by the following equations (7), (8) and (9).

$$V_a(t) = \begin{bmatrix} V_{\max}^z \sin(\omega t + \phi_z) \\ V_{\max}^p \sin(\omega t + \phi_p) \\ V_{\max}^n \sin(\omega t + \phi_n) \end{bmatrix} \quad (7)$$

$$V_b(t) = \begin{bmatrix} V_{\max}^z \sin(\omega t + \phi_z) \\ V_{\max}^p \sin(\omega t + \phi_p - 120) \\ V_{\max}^n \sin(\omega t + \phi_n + 120) \end{bmatrix} \quad (8)$$

$$V_c(t) = \begin{bmatrix} V_{\max}^z \sin(\omega t + \phi_z) \\ V_{\max}^p \sin(\omega t + \phi_p + 120) \\ V_{\max}^n \sin(\omega t + \phi_n - 120) \end{bmatrix} \quad (9)$$

Where,  $V_{\max}^z$ ,  $V_{\max}^p$  and  $V_{\max}^n$  represents the maximum voltage at the zero, positive and negative sequence of the three phase systems respectively.

$$\begin{bmatrix} v_a(t) \\ V_b(t) \\ V_c(t) \end{bmatrix} = \begin{bmatrix} y_{11} & y_{12} & y_{13} & y_{14} & y_{15} & y_{16} \\ y_{21} & y_{22} & y_{23} & y_{24} & y_{25} & y_{26} \\ y_{31} & y_{32} & y_{33} & y_{34} & y_{35} & y_{36} \end{bmatrix} \begin{bmatrix} V_{\max}^z \cos(\phi_z) \\ V_{\max}^z \sin(\phi_z) \\ V_{\max}^p \cos(\phi_p) \\ V_{\max}^p \sin(\phi_p) \\ V_{\max}^n \cos(\phi_n) \\ V_{\max}^n \sin(\phi_n) \end{bmatrix} \quad (10)$$

In the above equation  $y_{ij}$  is the  $i^{\text{th}}$  and  $j^{\text{th}}$  element of the measurement matrix.. To choose the symmetrical component based on functions as state variables, the state vector variables are communicated as,

$$A(t) = \begin{bmatrix} a_1(t) \\ a_2(t) \\ a_3(t) \\ a_4(t) \\ a_5(t) \\ a_6(t) \end{bmatrix} = \begin{bmatrix} V_{\max}^z \cos(\phi_z) \\ V_{\max}^z \sin(\phi_z) \\ V_{\max}^p \cos(\phi_p) \\ V_{\max}^p \sin(\phi_p) \\ V_{\max}^n \cos(\phi_n) \\ V_{\max}^n \sin(\phi_n) \end{bmatrix} \quad (11)$$

Where,  $a_i(t)$  is the elements of the  $i^{\text{th}}$  ( $i=1, 2, \dots, 6.$ ) state variable. The estimation condition of the recommended DVR system can be determined in simplified form as,

$$X(t) = Y(t).A(t) \quad (12)$$

Where,  $X(t)$  is the measured three phase supply voltage at time instant  $t$ ,  $Y(t)$  is the measurement matrix and  $A(t)$  is the state vector variables of the symmetrical component systems. From equation (12), it states that state variables are the sine or cosine functions of sequence component's amplitude and its phase angles. At the point when the deviation in voltage happens in the load side of the distribution system, the system fault voltages in any instant of time  $t$  is communicated as,

$$V_f^{sys}(t) = V_N^{sys}(t) \pm V_{f_m}(t) \quad (13)$$

Where,  $V_N^{sys}(t)$  and  $V_{f_m}(t)$  represents the normal system voltage and the magnitude of fault voltage instant of time  $t$  respectively. Now time  $t$  is in a range of  $t_{\min} \leq t \leq t_{\max}$ . The voltage deviation might be a high value or low value than the normal system voltage and it can be balanced by fluctuating the duty cycle of the

converter. The system fault voltage significantly relies on the injection voltage of the DVR. The DVR injection voltage is balanced by fluctuating the duty cycle of the switching circuit. The alteration of the duty cycle relies upon the accompanying conditions,

$$D_{cy} = \begin{cases} \text{if } V_f^{sys}(t) > V_N^{sys}(t); \text{ then } D(t) = 0 \\ \text{or else,} \\ \text{if } V_f^{sys}(t) < V_N^{sys}(t); \text{ then } D(t) = 1 \end{cases} \quad (14)$$

Where,  $D_{cy}$  represents the duty cycle of the converter and  $D(t)$  represents the duty cycle at the time instant  $t$ . Duty cycle decides the operation time depending on the fault voltage condition of the system. When  $V_f^{sys}(t)$  is greater than the normal system voltage,  $D_{cy}$  requires minimum operating cycle. When  $V_f^{sys}(t)$  is lesser than the normal system voltage,  $D_{cy}$  requires maximum operating cycle. However, this adjustment of the duty cycle is accomplished by the proposed MGSA algorithm. The accompanying area quickly clarified about the proposed control algorithm based DVR connected system.

#### B. The Proposed MGSA Control Approach

GSA is one of the most up to date heuristic algorithms that were roused by the physical laws [31]. In GSA, Newtonian laws of motion and gravity are utilized to accomplish the ideal arrangement utilizing a set of agents named as objects and their execution is measured by their masses. In GSA procedure, the output data set gotten from the goal of SNR is very much trained by the ANN algorithm keeping in mind the end goal to enhance the execution of the DVR. Henceforth this technique is named as the MGSA. *Steps Of GSA Based Dataset Generation*

##### FVF Step 1: Initialize

In this step, the filter is initialized. The input of the algorithm is given as the filter coefficients and the population  $X_f$  is initialized at the particular range of limits.

$$X_f = \left\{ V_{coef}^{\min} \leq V_{coef} \leq V_{coef}^{\max} \right\} \quad (15)$$

Where,  $V_{coef}^{\min}$  and  $V_{coef}^{\max}$  represents the range of min and max value of filter coefficient of system voltage and  $X_f$  denotes the initial population.

##### Step2. Random generation

Here, the coefficient ( $V_{coef}^{nm}$ ) values are initialized as the random generation of filter parameters.

$$R_f = \begin{bmatrix} V_{coef}^{11} & V_{coef}^{12} & \dots & V_{coef}^{1n} \\ V_{coef}^{21} & V_{coef}^{22} & \dots & V_{coef}^{2n} \\ \vdots & \vdots & \vdots & \vdots \\ V_{coef}^{m1} & V_{coef}^{m2} & \dots & V_{coef}^{mn} \end{bmatrix} \quad (16)$$

*Step 3:* Set the iteration count as  $i=i+1$  where,  $i=1,2,3,\dots$

##### Step 4: Fitness Function

As mentioned in the following, maximizing the SNR is the objective function of the proposed method. The general expression for SNR is given by,

$$F_{abc} = \text{Max(SNR)} = \frac{V_{signal}}{V_{noise}} \quad (17)$$

Where,  $V_{signal}$  and  $V_{noise}$  represents the ratio between the signal and noise of the voltage respectively. The process gets optimized once the maximum objective function is achieved and the corresponding filter parameters are tuned.

##### Step 5: Updating process

From the fitness function, the best and worst parameters of the inputs are updated. The best fitness and the worst fitness are described by the following equations.

$$F_B = \min_{j \in \{1, \dots, s\}} fit_j(t) \quad (19)$$

$$F_w = \max_{j \in \{1, \dots, s\}} fit_j(t) \quad (20)$$

Where,  $F_A$  and  $F_B$  represents the best and worst fitness, from the above calculations check the fitness of the new parameter and memorize the best solution.

##### Step 6: Repeat

In this progression, the strategy is rehashed until the point when the most extreme iteration is come to. The output is ordered as per their inputs and the coordinating yield is noted.

##### Step 7: Termination

Spare the ideal outcomes and boost the SNR objective for controlling the varieties. At that point spare the relating gain parameters of filter function. In light of the above strategies the gain parameter is ideally tuned. The above strides 1-6 are rehashed and the ideal outcomes are put away. To train the neural network structure the output of the algorithm is framed as the dataset. The Artificial Neural Network (ANN) is used for the active and reactive power generation. The output of the algorithm is meant as the accompanying,

$$\begin{bmatrix} V_{abc}^{11} & V_{abc}^{12} & \dots & V_{abc}^{1n} \\ V_{abc}^{21} & V_{abc}^{22} & \dots & V_{abc}^{2n} \\ \vdots & \vdots & \vdots & \vdots \\ V_{abc}^{m1} & V_{abc}^{m2} & \dots & V_{abc}^{mn} \end{bmatrix} = \begin{bmatrix} D_{cy}^{11} & D_{cy}^{12} & \dots & D_{cy}^{1n} \\ D_{cy}^{21} & D_{cy}^{22} & \dots & D_{cy}^{2n} \\ \vdots & \vdots & \vdots & \vdots \\ D_{cy}^{m1} & D_{cy}^{m2} & \dots & D_{cy}^{mn} \end{bmatrix} \quad (21)$$

In the condition, it unmistakably demonstrates that in view of the output dataset the duty cycle of the converter is balanced. The accompanying segment clarifies about the training procedure of the ANN.




Figure. 3 Process of MGSA Control Technique

### 1) Prediction of Duty Cycle using ANN

FFVDS In this segment, the best esteem generated by the GSA is additionally trained by the ANN to enhance the strength of the DVR. By and large, the set of training data for ANN is created by the real framework steadiness conduct. Be that as it may, in this work, the training data set is generated from the solutions of GSA and the input & output of the network is given by  $V_{abc}^{nm}(t)$  &  $D_{cy}^{nm}(t)$ .

Input layer, hidden layer and output layer are typically the three layer feed-forward neural networks [32]. For the modeling of ANN, Tangent Sigmoid Transfer Function is used at hidden layer and similarly linear transfer function is used at output layer .




Figure. 4 Structure of ANN

Fig. 4 represents the structure of the ANN in estimation of fitness function. In the hidden layer the procedure of ANN is performed. In this paper, the Back Propagation (BP) ANN training are utilized and the training data set of the network is given as, Input training data,

$$V_{abc}^{best} = \begin{bmatrix} V_{abc}^{11} & V_{abc}^{12} & \dots & V_{abc}^{1n} \\ V_{abc}^{21} & V_{abc}^{22} & \dots & V_{abc}^{2n} \\ \vdots & \vdots & \vdots & \vdots \\ V_{abc}^{m1} & V_{abc}^{m2} & \dots & V_{abc}^{mn} \end{bmatrix} \quad (22)$$

Output training data,

$$D_{cy}^{best} = \begin{bmatrix} D_{cy}^{11} & D_{cy}^{12} & \dots & D_{cy}^{1n} \\ D_{cy}^{21} & D_{cy}^{22} & \dots & D_{cy}^{2n} \\ \vdots & \vdots & \vdots & \vdots \\ D_{cy}^{m1} & D_{cy}^{m2} & \dots & D_{cy}^{mn} \end{bmatrix} \quad (23)$$

With the help of these data sets, the network is being trained and its output as  $D_{cy}^{ANN}$ . The steps are explained below.

*Step 1:* Initialize each neuron with the input, output and weight.

Here,  $V_{abc}^{best}$  &  $D_{cy}^{best}$  represent the input and output of the network.

*Step 2:* Determine the BP error by giving these data sets to the classifier which is given as follows,

$$BP_{err} = D_{cy}^{best} - D_{cy}^{ANN} \quad (24)$$

Where,  $D_{cy}^{best}$  is the target output and  $D_{cy}^{ANN}$  is the output of the network.

Step 3: The network output is calculated as,

$$D_{cy}^{ANN} = \varphi + \sum_{n=1}^N w_{2n1} D_{cy}^{ANN}(n) \quad (25)$$

$$D_{cy}^{ANN}(n) = \frac{1}{1 + \exp(-w_{1n} V_{abc}^{best})} \quad (26)$$

Equation (25) and (26) represents the activation function of output layer and hidden layer respectively.

Step 4: Weights of the neurons are varied by,  
 $w_{new} = w_{old} + \Delta w$ ,

Where,  $\Delta w$  is the change in weight, which can be determined as,

$$\Delta w = \chi \cdot D_{cy}^{ANN} \cdot BP_{err} \quad (27)$$

Where,  $\chi$  is the learning rate which varies from 0.2 to 0.5.

Step 5: Repeat the process from step 2, until  $BP_{err}$  gets minimized to a least value i.e.,

$$BP_{err} < 0.1 \quad (28)$$

The proposed methodology is simulated with MATLAB/simulink platform and the efficiency is analyzed which reveals the course of contrast with the supplementary procedure. With the effectiveness of the proposed HRES unit evaluated, the load voltage, positive sequence, real and reactive power is analyzed in the section IV.

#### IV RESULTS AND DISCUSSIONS

In this segment, the execution of the proposed MGSA strategy is actualized and dissected in MATLAB/Simulink working stage. The proposed strategy is utilized to enhance the PQ of the DVR associated distribution system with minimum injection. Here, the control system depends on the MGSA which upgrade the control algorithm for delivering the control signals of the DVR. With this control technique, unbalanced issues will be found with exactness and snappier execution to pull back out the PQ issue in sensitive load linked with distribution systems. Now the generated control signal by proposed procedure can deliver the upgraded control pulses can be used for enhancement of DVR. So as to execute the proposed control technique, the recreation comes about are contrasted and those of KF, EKF, PSO and ABC control techniques.

#### A. Performance Analysis

The adequacy of the proposed MGSA strategy is dissected to remunerate the changes caused by stack and the PQ issues. Additionally, the active and reactive power of DVR are repaid by the proposed outline. The execution of the proposed technique is tried under four instances. The proposed strategy is used to locate the ideal outcomes as depicted beneath.

##### Case A: Voltage Sag Condition

In the principal case, the voltage sag condition is investigated, the voltage sag happens primarily due the expanded utilization of power. The fluctuation in voltage may bring about the disappointment of the framework because of flimsy condition. Here, the source voltage, injected voltage, load voltage and positive sequence voltages are executed utilizing the proposed strategy. Fig. 5 demonstrates the proposed source voltage under faulted condition. Now, the voltage sag occurs amid the time interim between 0.1 to 0.2. Taking this into account, the end goal to remunerate the voltage sag the injected voltage of the DVR is upgraded with minimum injection. The execution of the injected voltage utilizing different methods like KF, EKF, PSO and ABC is dissected in fig. 6. By utilizing these procedures, the injected voltage of the DVR is upgraded at a specific level to remunerate the voltage sag. The execution of the injected voltage of the proposed MBSA is likewise appeared in fig. 6. By contrasting the injected voltage of the different procedures, the proposed strategy is greatly improved than the current systems. Fig. 7 demonstrates the load voltage proposed amid the voltage sag condition. It obviously demonstrates that the voltage at sag condition is practically repaid utilizing the proposed strategy. The positive sequence of the MGSA amid the voltage sag is appeared in fig. 8.




Figure. 5 Source Voltage Proposed at Voltage sag






Figure. 6 Injected voltage of (a) KF based DVR controller during Voltage Sag (b) EKF based DVR controller during Voltage Sag (c) PSO based DVR controller during Voltage Sag (d) ABC based DVR controller during Voltage Sag and (e) MBSA based DVR controller during Voltage Sag

The real and reactive power flow between the voltage sag conditions is deviated and the current procedures like KF, EKF, PSO and ABC. The correlation chart of the current systems with the proposed strategy is appeared in fig. 9 and 10. It demonstrates that by the proposed methodology that the real and reactive power is much remunerated and the MGSA technique is more appropriate to upgrade the PQ of the DVR.




Figure. 7 Load Voltage Proposed at Voltage sag




Figure. 8 Positive Sequence Proposed at Voltage sag




Figure. 9 Real Power Comparison at Voltage sag




Figure. 10 Reactive Power Comparison at Voltage sag

### Case B: Voltage at Unbalanced Condition

In the unbalanced condition, the deviation in the voltage happens because of the variety in the load. Subsequently the voltage at the fault condition should be adjusted. The investigation of the different procedures amid unbalance condition is given underneath. Fig.11 demonstrates the source voltage proposed at the unbalance condition. Here, the disturbance in voltage is between the interim 0.1 to 0.2. The different systems are produced to improve the voltage level at the unbalanced condition. In this area, a portion of the current systems of KF, EKF, PSO and ABC is dissected with proposed technique in the execution of the injected voltage which is appeared in fig. 12.




Figure. 11 Source Voltage Proposed at Unbalanced Condition

Fig. 14 and 15 demonstrates the correlation of active and reactive power of the current systems with the proposed



MGSA technique. From the examination, it demonstrates that the proposed technique is more prevalent than the current strategy in the remuneration of real and reactive power.




Figure. 12 Performance during unbalanced fault conditions (a) Injected voltage of KF based DVR controller (b) Injected voltage of EKF based DVR controller (c) Injected voltage of PSO based DVR controller (d) Injected Voltage of ABC based DVR controller and (e) Injected voltage of MBSA based DVR controller




Figure. 13 Positive Sequence voltage at Unbalanced Condition




Figure. 14 Real Power Comparison at Unbalanced Condition




Figure. 15 Reactive Power Comparison at Unbalanced Condition

*Case C: Phase – Phase fault condition*

This segment clarifies about the examination of the fault clearance utilizing the current methods amid the phase-phase fault condition. Here, the fault happens between the phases B and C, the BC fault happens fundamentally because of the short circuit between the two phases. Fig. 16 demonstrates the source voltage at the BC fault. In this, the event of fault between 0.1 to 0.2 is cleared by injecting the voltage by DVR utilizing distinctive existing procedures. The injected voltage execution of the current systems and the proposed strategy is appeared in fig. 17. Fig. 18 demonstrates the load voltage proposed at the phase to phase fault condition. From the diagram, it demonstrates that by the proposed strategy the load voltage is practically repaid with the ordinary voltage. The positive sequence response of the proposed technique is appeared in fig. 19.




Figure. 16 Source Voltage Proposed at BC fault




Figure. 17 Performance during BC fault (a) Injected voltage of KF based DVR controller (b) Injected voltage of EKF based DVR controller (c) Injected voltage of PSO based DVR controller (d) Injected Voltage of ABC

based DVR controller and (e) Injected voltage of MBSA based DVR controller




Figure. 18 Load Voltage Proposed at BC fault




Figure. 19 Positive Sequence Proposed at BC fault

. Finally the correlation graph is plotted utilizing the real and reactive power between the current systems. The examination demonstrates the need of the proposed strategy so as to enhance the execution of the DVR.




Figure. 20 Real Power Comparison at BC fault




Figure. 21 Reactive Power Comparison at BC fault

*Case D: Phase – Ground fault condition*

In this segment, the fault happens because of the improper insulation between the phase and the ground. The fig. 22 demonstrates the proposed source voltage amid the phase-ground fault i.e., A fault. Here, amid the interim between 0.1 to 0.2 the phase-phase fault is happened. For repaying the voltage at fault condition,

the execution of the injected voltage utilizing distinctive methods is appeared in fig. 23. The execution graph of different strategies demonstrates that the proposed technique requires least injection to remunerate the A fault. Fig. 24 and 25 demonstrates the load and positive sequence of the proposed MGSA technique. The diagram plainly clarifies the change in the voltage of 0.7V amid the fault condition by the proposed technique.




Figure. 22 Source Voltage Proposed at A fault




Figure. 23 Performance during A fault (a) Injected voltage of KF based DVR controller (b) Injected voltage of EKF based DVR controller (c) Injected voltage of PSO based DVR controller (d) Injected Voltage of ABC based DVR controller and (e) Injected voltage of MBSA based DVR controller




Figure. 24 Load Voltage Proposed at A fault




Figure. 25 Positive sequence Proposed at A fault

In fig. 26 the real power of the proposed strategy rapidly achieves the stable condition when contrasted and the current systems. At that point the output of the reactive power is investigated in the fig. 27




Figure. 26 Real Power Comparison at A fault




Figure. 27 Reactive Power Comparison at A fault

The proposed system rapidly achieves a steady operation at 300 W as contrasted and different techniques, for example, KF, EKF, PSO, ABC are 200, 250, 275 and 300 separately. From the general examination, the proposed strategy manages different disturbances and system vulnerabilities, for example, various loading conditions and severe faults. The valuation execution among as KF, EKF, PSO and ABC strategy is researched. This evaluation demonstrates that this methodology is the best technique to suspicious nonlinearity in this framework with more reliability, robust and easy execution when compared to alternate methodologies. In this manner, the execution of the proposed strategy has accomplished better outcomes.

## V CONCLUSION

In this paper, to explain the PQ issues in the distribution system of DVR, MGSA control strategy is proposed. For

limiting the real and reactive power varieties of the system the proposed control algorithm is suited very much. MATLAB/Simulink platform is utilized for modeling and recreations of the proposed procedure of DVR have been introduced. The proposed MGSA system is viable in getting ability to locate the ideal arrangements with high exactness. Here, the MGSA includes in two stages, for generating dataset utilizing GSA and for training the dataset for the expectation of duty cycle utilizing ANN. The execution of the proposed control technique is deviated and recent procedures like KF, EKF, PSO and ABC. From the execution examination, the MGSA based DVR can withhold the different fault condition like voltage sag, unbalanced fault, phase-phase fault and phase-ground fault.

## REFERENCES

- [1] E. Babaei and M. Farhadi Kangarlu, "Operation and control of dynamic voltage restorer using single-phase direct converter", *Energy Conversion and Management*, vol. 52, no. 8-9, pp. 2965-2972, 2011.
- [2] H. Al-Hadidi, A. Gole and D. Jacobson, "A Novel Configuration for a Cascade Inverter-Based Dynamic Voltage Restorer With Reduced Energy Storage Requirements", *IEEE Transactions on Power Delivery*, vol. 23, no. 2, pp. 881-888, 2008.
- [3] P. Roncero-Sanchez and E. Acha, "Dynamic Voltage Restorer Based on Flying Capacitor Multilevel Converters Operated by Repetitive Control", *IEEE Transactions on Power Delivery*, vol. 24, no. 2, pp. 951-960, 2009.
- [4] E. Babaei and M. Farhadi Kangarlu, "Voltage quality improvement by a dynamic voltage restorer based on a direct three-phase converter with fictitious DC link", *IET Generation, Transmission & Distribution*, vol. 5, no. 8, p. 814, 2011.
- [5] C. Sundarabalan and K. Selvi, "Compensation of voltage disturbances using PEMFC supported Dynamic Voltage Restorer", *International Journal of Electrical Power & Energy Systems*, vol. 71, pp. 77-92, 2015.
- [6] B. Delfino, F. Fornari and R. Procopio, "An Effective SSC Control Scheme for Voltage Sag Compensation", *IEEE Transactions on Power Delivery*, vol. 20, no. 3, pp. 2100-2107, 2005.
- [7] F. Badrkhani Ajaci, S. Farhangi and R. Iravani, "Fault Current Interruption by the Dynamic Voltage Restorer", *IEEE Transactions on Power Delivery*, vol. 28, no. 2, pp. 903-910, 2013.
- [8] Y. Li, D. Vilathgamuwa, P. Loh and F. Blaabjerg, "A Dual-Functional Medium Voltage Level DVR to Limit Downstream Fault Currents", *IEEE Transactions on Power Electronics*, vol. 22, no. 4, pp. 1330-1340, 2007.
- [9] P. Roncero-Sanchez, E. Acha, J. Ortega-Calderon, V. Feliu and A. Garcia-Cerrada, "A Versatile Control Scheme for a Dynamic Voltage Restorer for Power-Quality Improvement", *IEEE Transactions on Power Delivery*, vol. 24, no. 1, pp. 277-284, 2009.
- [10] A. Goswami, C. Gupta and G. Singh, "Minimization of voltage sag induced financial losses in distribution systems

- using FACTS devices", *Electric Power Systems Research*, vol. 81, no. 3, pp. 767-774, 2011.
- [11]F. Ajaei, S. Afsharnia, A. Kahrobaeian and S. Farhangi, "A Fast and Effective Control Scheme for the Dynamic Voltage Restorer", *IEEE Transactions on Power Delivery*, vol. 26, no. 4, pp. 2398-2406, 2011.
- [12]M. Moradlou and H. Karshenas, "Design Strategy for Optimum Rating Selection of Interline DVR", *IEEE Transactions on Power Delivery*, vol. 26, no. 1, pp. 242-249, 2011.
- [13]F. Mahdianpoor, R. Hooshmand and M. Ataei, "A New Approach to Multifunctional Dynamic Voltage Restorer Implementation for Emergency Control in Distribution Systems", *IEEE Transactions on Power Delivery*, vol. 26, no. 2, pp. 882-890, 2011.
- [14]M. Nabipour, M. Razaz, S. Seifossadat and S. Mortazavi, "A novel adaptive fuzzy membership function tuning algorithm for robust control of a PV-based Dynamic Voltage Restorer (DVR)", *Engineering Applications of Artificial Intelligence*, vol. 53, pp. 155-175, 2016.
- [15]J. Roldan-Perez, A. García-Cerrada, J. Zamora-Macho, P. Roncero-Sanchez and E. Acha, "Troubleshooting a digital repetitive controller for a versatile dynamic voltage restorer", *International Journal of Electrical Power & Energy Systems*, vol. 57, pp. 105-115, 2014.
- [16]J. Roldan-Perez, A. Garcia-Cerrada, M. Ochoa-Gimenez and J. Zamora-Macho, "On the Power Flow Limits and Control in Series-Connected Custom Power Devices", *IEEE Transactions on Power Electronics*, vol. 31, no. 10, pp. 7328-7338, 2016.
- [17]D. Fernandes, F. Costa and M. Vitorino, "A Method for Averting Saturation From Series Transformers of Dynamic Voltage Restorers", *IEEE Transactions on Power Delivery*, vol. 29, no. 5, pp. 2239-2247, 2014.
- [18]O. Prakash Mahela and A. Gafoor Shaik, "Topological aspects of power quality improvement techniques: A comprehensive overview", *Renewable and Sustainable Energy Reviews*, vol. 58, pp. 1129-1142, 2016.
- [19]M. Marei, A. Eltantawy and A. El-Sattar, "An energy optimized control scheme for a transformerless DVR", *Electric Power Systems Research*, vol. 83, no. 1, pp. 110-118, 2012.
- [20]A. Jindal, A. Ghosh and A. Joshi, "Critical load bus voltage control using DVR under system frequency variation", *Electric Power Systems Research*, vol. 78, no. 2, pp. 255-263, 2008.
- [21] S. Agalar and Y. Kaplan, "Power quality improvement using STS and DVR in wind energy system", *Renewable Energy*, 2017.
- [22]S. Swain and P. Ray, "Short circuit fault analysis in a grid connected DFIG based wind energy system with active crowbar protection circuit for ride through capability and power quality improvement", *International Journal of Electrical Power & Energy Systems*, vol. 84, pp. 64-75, 2017.
- [23]S. Narula, B. Singh, G. Bhuvaneswari and R. Pandey, "Improved Power Quality Bridgeless Converter-Based SMPS for Arc Welding", *IEEE Transactions on Industrial Electronics*, vol. 64, no. 1, pp. 275-284, 2017.
- [24]D. Li, K. Yang, Z. Zhu and Y. Qin, "A Novel Series Power Quality Controller With Reduced Passive Power Filter", *IEEE Transactions on Industrial Electronics*, vol. 64, no. 1, pp. 773-784, 2017.
- [25]V. Khadkikar, D. Xu and C. Cecati, "Emerging Power Quality Problems and State-of-the-Art Solutions", *IEEE Transactions on Industrial Electronics*, vol. 64, no. 1, pp. 761-763, 2017.
- [26]H. Hafezi, G. D'Antona, A. Dede, D. Della Giustina, R. Faranda and G. Massa, "Power Quality Conditioning in LV Distribution Networks: Results by Field Demonstration", *IEEE Transactions on Smart Grid*, vol. 8, no. 1, pp. 418-427, 2017.
- [27]K. Venkatraman, S. Moorthi and M. Selvan, "Modelling and Control of Transformer-less Universal Power Quality Conditioner (TUnPQC): An Effective Solution for Power Quality Enhancement in Distribution System", *Journal of Control, Automation and Electrical Systems*, vol. 28, no. 1, pp. 123-134, 2016.
- [28]M.Talaat, M A Farahat and M.H.Elkholy Renewable power integration: Experimental and simulation study to investigate the ability of integrating wave, solar and wind energies. 170C (2019) pp. 668-682.
- [29] M.Talaat, A.Y.Hatata,Abdulaqziz, S.Alsayyari,Adel alblawi A smart load management system based on the grasshopper optimization algorithm using the under-frequency load shedding approach. *Energy*, Article 116423
- [30] Z. Li, W. Li and T. Pan, "An optimized compensation strategy of DVR for micro-grid voltage sag", *Protection and Control of Modern Power Systems*, vol. 1, no. 1, 2016.
- [31]F. Farivar and M. Shoorehdeli, "Stability analysis of particle dynamics in gravitational search optimization algorithm", *Information Sciences*, vol. 337-338, pp. 25-43, 2016.
- [32] V. Tamilselvan and T. Jayabarathi, "A hybrid method for optimal load shedding and improving voltage stability", *Ain Shams Engineering Journal*, vol. 7, no. 1, pp. 223-232, 2016.